



NOTES:

- 1- Refill by reversing flow through hydrant until water spills out overflow.
- 2- Drafting will be required once the water level drops below the hydrant.

NOT TO SCALE, FOR ILLUSTRATION ONLY

Rev Date 4/18/2020	MOUNDED BURY 160,000 GAL. MULTIPAL TANK FIRE CISTERN	Sheet 1 of 1
Rev Let INT. REL.	Darco Incorporated Post Office Box 68 Cottonwood, AZ 86326 800-232-8660 - www.darcoinc.com	